



Jeremiah W. (Jay) Nixon, Governor

Sara Parker Pauley, Director

## DEPARTMENT OF NATURAL RESOURCES

[dnr.mo.gov](http://dnr.mo.gov)

October 1, 2013

Mr. Marlin Constance  
Stoney Point Association  
300 Slane Chapel Rd.  
Branson West, MO 65737

Dear Permittee:

Missouri State Operating Permit MO-0125971 issued on November 25, 2011, is hereby modified as per the enclosed. This modification is to include dechlorination and new Total Residual Chlorine limits and remove of schedule of compliance for Total Residual Chlorine. The enclosed permit is for your official record.

Please read your permit and enclosed Standard Conditions. They contain important information on monitoring requirements, effluent limitations, sampling frequencies and reporting requirements.

This permit is both your Federal Discharge Permit and your new State Operating Permit and replaces all previous State Operating Permits for this facility. In all future correspondence regarding this facility, please refer to your State Operating Permit number and facility name as shown on page one of the permit.

**Please be aware that nothing in this permit relieves the permittee of any other legal obligations or restrictions, such as other federal or state laws, court orders, or county or other local ordinances or restrictions.**

If you were adversely affected by this decision, you may be entitled to an appeal before the administrative hearing commission pursuant to 10 CSR 20-1.020 and Section 621.250, RSMo. To appeal, you must file a petition with the administrative hearing commission within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the administrative hearing commission. Any appeal shall be directed to: Administrative Hearing Commission, Truman Building, Room 640, 301 W. High Street, P.O. Box 1557, Jefferson City, MO 65102, Phone: 573-751-2422, Fax: 573-751-5018, website: [www.oa.mo.gov/ahc](http://www.oa.mo.gov/ahc).



Recycled Paper

Mr. Marlin Constance  
Stoney Point Association  
Page 2

If you have questions concerning this permit please contact Mr. Sieu T. Dang of my staff by calling 417-891-4300 or via mail at Southwest Regional Office, 2040 W. Woodland, Springfield, MO 65807-5912.

Sincerely,

SOUTHWEST REGIONAL OFFICE

A handwritten signature in cursive script that reads "Cynthia S. Davies".

Cynthia S. Davies  
Regional Director

CSD/sdk

Enclosures

STATE OF MISSOURI  
DEPARTMENT OF NATURAL RESOURCES  
MISSOURI CLEAN WATER COMMISSION



## MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No. MO-0125971

Owner: Stoney Point Association  
Address: 300 Slane Chapel Road, Branson West, MO 65737

Continuing Authority: Same as Above  
Address: Same as Above

Facility Name: Stoney Pointe WWTF  
Facility Address: 300 Slane Chapel Road, Branson West, MO 65737

Legal Description: NE¼, SE¼, Sec. 14, T22N, R23W, Stone County  
UTM (X/Y): 465503 / 4051216

Receiving Stream: Tributary to Table Rock Lake (U)  
First Classified Stream and ID: Table Rock Lake (L2) (07313) 303(d)  
USGS Basin & Sub-watershed No.: (11010001-1401)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

### FACILITY DESCRIPTION

Outfall #001 - Subdivision - SIC #8641

The use or operation of this facility does not require a CERTIFIED OPERATOR.

Recirculating sand filter / chemical addition for phosphorus removal / chlorination / dechlorination / sludge is hauled.

Design organic population equivalent is 33

Design flow is 0.003330 MGD

Design sludge production is 0.33 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

November 25, 2011      October 1, 2013  
Effective Date      Revised

  
Sara Parker Pauley, Director, Department of Natural Resources

November 24, 2016  
Expiration Date

  
Cynthia S. Davies, Regional Director, Southwest Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)					PAGE NUMBER 2 of 4	
					PERMIT NUMBER MO-0125971	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective <b>upon issuance</b> and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/quarter**	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		30	20	once/quarter**	grab
Total Suspended Solids	mg/L		30	20	once/quarter**	grab
pH – Units	SU	***		***	once/quarter**	grab
<i>E. coli</i> ( <b>Note 1</b> )	#/100 ml	630		126	once/quarter**	grab
Total Residual Chlorine as Cl <sub>2</sub>	µg/L	17 ( <b>Note 2</b> ) (130 ML)		8 ( <b>Note 2</b> ) (130 ML)	once/quarter**	grab
Ammonia as N	mg/L	*		*	once/quarter**	grab
Aluminum, Total Recoverable ( <b>Note 3</b> )	µg/L	*		*	once/quarter**	grab
Iron, Total Recoverable ( <b>Note 3</b> )	µg/L	*		*	once/quarter**	grab
Total Phosphorus as P	mg/L			0.5	once/quarter**	grab
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	DAILY MINIMUM	WEEKLY AVERAGE MINIMUM	MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfall #001						
Dissolved Oxygen	mg/L	*		*	once/quarter**	grab
MONITORING REPORTS SHALL BE SUBMITTED <b>QUARTERLY</b> ; THE FIRST REPORT IS DUE <b>JANUARY 28, 2014</b> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- \* Monitoring requirement only.
- \*\* Sampling shall occur once per quarter in the periods of January through March, April through June, July through September, and October through December, please note that monitoring reports shall be submitted no later than the 28th day of the month following the monitoring period (April 28th, July 28th, October 28th, and January 28th, respectively).
- \*\*\* pH is measured in pH units and is not to be averaged. The pH for all facilities except lagoons is limited to the range of 6.5-9.0 pH units.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

Note 1 - Final limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a geometric mean. Geometric mean for n samples =  $[a_1 \times a_2 \times a_3 \dots \times a_n]^{1/n}$

Note 2 - This permit contains a Total Residual Chlorine (TRC) limit.

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 130 µg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 130 µg/L will be considered violations of the permit and values less than the minimum quantification level of 130 µg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- (b) Disinfection is required year-round unless the permit specifically states that “Final limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31.” If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.
- (c) Do not chemically dechlorinate **if it is not needed to meet the limits in your permit.**
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as “0 mg/L” TRC.

Note 3 - If no Aluminum or Iron was used in a given sampling period, an actual analysis is not necessary. Simply report as “0 mg/L”.

C. SPECIAL CONDITIONS

- 1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri’s Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri’s list of waters of the state not fully achieving the state’s water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

- 2. All outfalls must be clearly marked in the field.
- 3. Permittee will cease discharge by connection to a facility with an area-wide management plan per 10 CSR 20-6.010(3)(B) within 90 days of notice of its availability.
- 4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

C. SPECIAL CONDITIONS (continued)

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
    - (1) One hundred micrograms per liter (100 µg/L);
    - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
    - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
    - (4) The level established in Part A of the permit by the Director.
  - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.
6. Water Quality Standards
- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
  - (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
    - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
    - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
    - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
    - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
    - (5) There shall be no significant human health hazard from incidental contact with the water;
    - (6) There shall be no acute toxicity to livestock or wildlife watering;
    - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
    - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

**Missouri Department of Natural Resources**  
**Statement of Basis**  
**Stoney Pointe WWTF**  
**MSOP #: MO-0125971**  
**Stone County**

This Statement of Basis (Statement) gives pertinent information regarding minor/simple modification(s) to the above listed operating permit without the need for a public comment process.

A Statement is not an enforceable part of an operating permit.

**FACILITY DESCRIPTION**

Recirculating sand filter / chemical addition for phosphorus removal / chlorination / dechlorination / sludge is hauled.

Design organic population equivalent is 33  
Design flow is 0.003330 MGD  
Design sludge production is 0.33 dry tons/year.

**MODIFICATION RATIONALE**

This operating permit is hereby modified to include dechlorination in the facility description and new Total Residual Chlorine limits. The interim effluent limitations table and the Schedule of Compliance were removed as they were no longer pertinent.